



## **SECTION A-A**

## SPECIFICATIONS:

- (1) COVER: 14 GAUGE GALVANNEAL COVER STIFFENED TO WITHSTAND A LIVE LOAD OF 40 PSF WITH A MAX DEFLECTION OF 1/150 OF THE SPAN
- 2 LINER: 14 GAUGE GALVANNEAL
- 3 CURB AND COUNTERFLASH W/ EZ TAB:

DBL WALL CURB, 14 GAUGE GALVANNEAL

4 FINISH: COVER -

POWDER COAT, GRAY EXTERIOR, BLACK INTERIOR CURB - POWDER COAT, BLACK

- (5) **GAS SPRING WITH DAMPER**: DESIGNED TO OPEN AGAINST A 10PSF SNOW LOAD IN NOT LESS THAN 2 SECONDS
- 6 HOLD OPEN ARM: LOCKS COVER IN FULLY OPEN POSITION -ZINC PLATED STEEL
- (7) LATCH: ZINC PLATED ROTARY LATCH ASSEMBLY DESIGNED TO HOLD COVERS CLOSED AGAINST 90 PSF WIND UPLIFT ZINC PLATED STEEL LATCH STRIKERS ON COVERS

- (8) HINGES: 304 STAINLESS STEEL BUTT HINGE WITH 1/4" PIN
- (9) INSULATION: MINERAL WOOL W/ SOUND MAT, R-VALUE 10
- (10) GASKETS: ADHESIVE BACKED EPDM RUBBER EXTRUSION ON **CURB AND COVER**
- 11 THERMAL RELEASE MECHANISM: VENT COVERS OPEN THERMALLY BY HEAT AT FUSIBLE LINK TEMPERATURE 165F°F 12 MANUAL OPERATION:

VENT COVERS OPEN WITH INTERNAL AND EXTERNAL MANUAL PULL HANDLES, 1/16" DIA SST CABLE, CLOSE VENT AT ROOFTOP

13 ELECTRICAL RELEASE:

VENT COVERS OPEN ELECTRICALLY WHEN ENERGIZED WITH 24VAC/VDC

- 14 BURGLAR BARS: NONE
- 15 **SOUND RATING**: STC48 PER ASTME90, OITC 36 PER ASTME1332

SMOKE VENT SIZE "(WIDTH) x "(LENGTH)

**EFFECTIVE VENTING AREA 80%** 

´ 2 ` 11

	PROJECT:						
	ARCHITECT:						
	CONTRACTOR:						
		QTY:					
	PART#:						
9300 73rd Avenue North Minneapolis, MN 55428				m	TITLE: Smoke Vent, Acoustical STC48,		
					Galvn Steel, Black Pwd, Gray Pwd Cvr Ext, Dbl Wall Curb,		
		NAME	DATE	SIZE	DWG. NO.		REV
	DRAWN	ELW	4/15/14	Α			A
	RELEASED	ELW	4/15/14	WE	IGHT: VARIES	SHEET 1	OF 2

PROPRIETARY AND CONFIDENTIAL: THE INFORMATION CONTAINED IN THIS DRAWING IS THE SOLE PROPERTY OF NYSTROM. ANY REPRODUCTION IN PART OR AS A WHOLE WITHOUT THE WRITTEN PERMISSION OF NYSTROM IS PROHIBITED.

