



**EJN-FLW140 SERIES**

- (2" JOINT OPENING : P/N = EJN-FLW140-200)
- (3" JOINT OPENING : P/N = EJN-FLW140-300)
- (4" JOINT OPENING : P/N = EJN-FLW140-400)

**EJN-FLW140 SERIES**

- (2" JOINT OPENING : P/N = EJN-FLW140-200)
- (3" JOINT OPENING : P/N = EJN-FLW140-300)
- (4" JOINT OPENING : P/N = EJN-FLW140-400)

**SEISMIC FIRE BARRIER WALL SYSTEM**

- HORIZONTAL MOVEMENT: +/-50% (TOTAL = 100%)
- STOCK LENGTHS: 6.5 FT (2.0M) INCREMENTS
- STANDARD WALL-TO-WALL RATING MUST BE IN COMPLIANCE WITH UL REQUIREMENTS (BY OTHERS)
- LISTED BY INTERTEK USA/CANADA 2HR RATING
- MEETS UL 2079, ULC S-115, ASTM E-1399 AND ASTM E-1966-01
- ALL SIZES (2", 3" & 4") AVAILABLE WITH A 2HR RATING.

**THIS FIRE BARRIER IS TESTED WITH A METAL COVER. IN AREAS WHERE ONLY ELASTOMERIC OR NO COVERS ARE USED, WE CAN PROVIDE A STAINLESS-STEEL FOIL TO MAINTAIN THE RATING**



PROPRIETARY AND CONFIDENTIAL: THE INFORMATION CONTAINED IN THIS DRAWING, IS SOLE PROPERTY OF NYSTROM. ANY REPRODUCTION IN PART OR AS A WHOLE, WITHOUT THE WRITTEN PERMISSION OF NYSTROM, IS PROHIBITED. © 2020 NYSTROM, INC.

PROJECT:			
ARCHITECT:			
CONTRACTOR:			
QTY:			
PART#:		EJN-FLW140 SERIES	
 9300 73 <sup>rd</sup> Ave N., Minneapolis, MN 55428 800-547-2635 info@nystrom.com		TITLE: SEISMIC FIRE BARRIER WALL SYSTEM INSIDE APPLICATION 2 HOUR RATED	
	NAME	DATE	SIZE
DRAWN	JPK	03/13/24	A
RELEASED			
DWG. NO.			REV
<b>EJN-FLW140 SERIES</b>			<b>A</b>
WEIGHT:			SHEET 1 OF 1