



Direct Service Done Right



**MODELS**

MODEL	DESCRIPTION
EM-SFI-13X18	Floor ID Sign

# Safe-T-Lume™

## FLOOR ID SIGN

Safe-T-Lume Floor ID Signs are custom made for your building. These signs are made of the same photoluminescent material as the running man signs. The stair letters are at least 1-1/2 inches tall and the other letters are at least 1 inch in height as required per Section 1022.8.1 Sub 6.

**DETAILS**

**MATERIAL** Vinyl


**COLOR** Photoluminescent and black

**MOUNTING** Surface, Adhesive Tabs or Mechanically Fastened

**SIZE** 13 inches by 18 inches

**CODE COMPLIANCE** 2015/2018 IBC Section 1023, 2015/2018 IFC Section 1023, and 2014 NYC BC Section 1022.8

**TEST STANDARD** UL 1994



# Safe-T-Lume™

## NOT AN EXIT SIGN

The Safe-T-Lume Not an Exit Sign is designed to mark doors in an egress stairway that are not an exit door. These signs are constructed with a photoluminescent vinyl that collects and stores ambient light and glows during a blackout or smokey conditions.

**DETAILS**

**MATERIAL** Vinyl


**COLOR** Photoluminescent, black and red

**MOUNTING** Surface, Adhesive Tabs, or Mechanically Fastened

**SIZE** 5-1/2 inches by 6-1/2 inches

**CODE COMPLIANCE** 2014 NYC BC Section 1024

**TEST STANDARD** UL 1994



**MODELS**

MODEL	DESCRIPTION
EM-SNE-5.5X6.5	Not an Exit Sign